

**Green Acres Facility**  
**Asbestos survey summary table**

Survey Date: August 2011

Reinspection Date: December 2011

Survey professional: John Pardee, JP Incorporated

Area/Room #	ACM Floor Tile (sq.ft.)	ACM Sheet flooring (sq. ft.)	ACM TSI	Other
<b>Senior Girls Wing (West Wing)</b>				
First Floor Level				20 brown firre doors
Girls RR #1				
Room 1	180			1 light insulator
Relief house parent	210			
House parent apt. (bedroom)	155			2 light insulators
Room 2	180			1 light insulator
Girls RR #2				1 light insulator
Room 3	180			1 light insulator
Room 4	180			1 light insulator
Room 5	210			1 light insulator
Room 6	180			1 light insulator
TV Room				
Room 7	375			2 light insulators
Mud Room	180			
Cubby				1 light insulator
<b>UNIT TOTALS</b>	<b>2,030</b>	<b>0</b>	<b>0</b>	<b>12 light insulators</b>

<b>Senior Boys Wing (East Wing)</b>				
Play therapy	143			
Observation				55 sq. ft. mastic
Reception area				192 sq. ft. mastic
Conference room				156 sq. ft. mastic
Lobby & hallway		818		
Employee RR				1 light insulator
Visitors				
Mud room	75			
Room 1	180			1 light insulator
Boys RR #1				
Janitors closet	16			
Room 2	180			1 light insulator
House parent apt. (bedroom)	140			2 light insulators
Relief house parent	144			
Room 3	180			1 light insulator
Boys RR #2				1 light insulator
Room 4	180			1 light insulator
Room 5	210			1 light insulator
Room 6	180			1 light insulator
TV Room				
Room 7	323			2 light insulators
Cubby				1 light insulator
<b>UNIT TOTALS</b>	<b>1,951</b>	<b>818</b>	<b>0</b>	<b>13 light insulators; 403 sq. ft. mastic</b>

**Green Acres Facility  
Asbestos survey summary table**

Area/Room #	ACM Floor Tile (sq.ft.)	ACM Sheet flooring (sq. ft.)	ACM TSI	Other
<b>JUNIOR DORM (South Wing)</b>				
Director's Office			Roof drain; 11 large	1 light insulator
South hallway		240		
Room 1	180			1 light insulator
Boys RR #1				1 light insulator
Room 2	180			1 light insulator
Relief House Parent	210			1 light insulator
House Parent apt. (bedroom)	140			1 light insulator
Room 3	180			1 light insulator
Girls RR #1	10			2 light insulators
Room 4	180			
Room 5	180			
Living Room	792			
Room 6	180			1 light insulator
Room 7	456			
Closets in hallway	32			
<b>UNIT TOTALS</b>	<b>2,720</b>	<b>240</b>	<b>Roof drain; 11 pji</b>	<b>10 light insulators</b>
<b>DINING WING (North Wing)</b>				
Storage #1	120			
Storage #2	128			
Dining Room		1,200		
Storage #3				2 vibration isolators
Kitchen				
Freezer/Cooler				
Restroom	25			
Hallway		104		
<b>UNIT TOTALS</b>	<b>273</b>	<b>1,304</b>	<b>0</b>	<b>2 vibration isolators</b>
<b>BASEMENT</b>				
Basement Level				16 brown fire doors
Sr. boys rec room				4 light insulators
Storage; Shop; Rec Room; Laundry				
Hallway off laundry				1 light insulator
Junior rec room				
Senior girls rec				
Mat storage				
Boiler #1			50 large diam. fittings; 300 sq.ft. flu pipe; 2 boilers	
Boiler #2			16 large	
Crawl space				
<b>UNIT TOTALS</b>	<b>0</b>	<b>0</b>	<b>66 large; 300 sf flu pipe</b>	<b>5 light insulators</b>
<b>TOTALS</b>	<b>6,974 sq.ft. tile and mastic</b>	<b>2,362 sq. ft. sheet flooring</b>	<b>77 large pji; 300 sq.ft. flu pipe; 1 roof drain; 2 boilers</b>	<b>2 vibration isolators; 40 light insulators; 36 brown fire doors; 403 sq. ft. mastic only (under non-ACM tile)</b>